

DOCUMENT 00 00 11

**ADDENDUM NO. 1
May 25, 2018**

**South Rivanna WTP - Residuals Clarifiers Decant System Installation
RFQ No. 1076
Rivanna Water & Sewer Authority**

SEH No. RIVAN 145827

From: Short Elliott Hendrickson Inc.
3535 Vadnais Center Drive
Saint Paul, MN 55110-5196

To: Document Holders

DOCUMENT HOLDERS on the above-named project are hereby notified that this document shall be appended to, take precedence over and become part of the original quotation documents dated May 10, 2018 for this work. Quotations submitted for the construction of this work shall conform to this document.

This addendum consists of 1 page.

Clarifications and Notes:

1. The majority of the clarifiers are below grade.
2. The wall angle pipe supports shall have a backing plate attached to the support. Adhesive wall anchors shall be used to attach the pipe supports to the walls. Anchoring systems that fully penetrate the clarifier wall shall not be allowed.
3. The clarifiers take approximately 48 hours to fully drain. The 24 hour working window allowed in the specifications for work inside each clarifier will begin after the clarifiers are drained.
4. The use of supplier-stocked fittings and reducers will be allowed for the transition from the existing 18-inch pipe to the new 6-inch piping to be installed in lieu of the 18x6 reducing elbow shown in the Drawings.

Changes to Drawings:

5. Revised Sheets P1 and P2 will be issued on May 29, 2018. Revisions to piping in the North Clarifier will include installation of a spacer between the existing 18-inch wall pipe and new elbow to be installed. An eccentric reducer connected to the 18-inch elbow will be used to push the centerline of the 6-inch piping towards the center of the clarifier. The changes are being made to avoid conflicts with existing pipe support brackets and vertical piping.

Note: Receipt of this Addendum No. 1 (dated May 25, 2018) shall be acknowledged on Page 00 41 00-1 of the submitted Quote Form. Failure to do so may subject Quoter to disqualification.

END OF ADDENDUM